

Message

From: Pat Hunt [WaterSewerSupvr@badriver-nsn.gov]
Sent: 7/16/2014 2:36:03 PM
To: Colletti, John [colletti.john@epa.gov]
Subject: RE: WWTP Lagoon

Thank you sir.

From: Colletti, John [mailto:colletti.john@epa.gov]
Sent: Wednesday, July 16, 2014 9:35 AM
To: Pat Hunt
Cc: Maraldo, Dean
Subject: RE: WWTP Lagoon

Except for the phosphorus, everything looks good. Go ahead and start the discharge at no more than 6 inches per day with monitoring the effluent at least twice a week. Hopefully the phosphorus levels will go down as you discharge.

From: Pat Hunt [mailto:WaterSewerSupvr@badriver-nsn.gov]
Sent: Wednesday, July 16, 2014 9:04 AM
To: Colletti, John
Cc: Maraldo, Dean
Subject: WWTP Lagoon

Here are the pre – discharge numbers for the WWTP lagoon. We intend on beginning lowering the lagoon tomorrow (Thursday, July 17 2014) with your permission.

Patrick Hunt
Bad River Utility